



LAKE COUNTY FOREST PRESERVES

---

Preservation, Restoration, Education and Recreation

DATE: December 13, 2017

**ADDENDUM NO. 2**

INVITATION FOR BID NO. 18006

PROJECT: Public Access Improvements – Ethel’s Woods Forest Preserve

BID OPENING DATE: December 19, 2017

BID OPENING TIME: 10:00 a.m.

**Please note the following clarifications, revisions, and additions to the bid documents:**

1. QUESTION: The contour file provided by the engineer seems to be corrupt.

ANSWER: The files are located at the following link (see Addenda No. 1)

<https://civiltechftp.exavault.com/share/view/2116-b7qsvm4u>

The Contours\_Ex.dgn file is an updated version replacing the old copy with the same name.

The Jorgensen\_Svy.tin file is the existing ground TIN as provided by the surveyor.

2. QUESTION: The proposed path profile on Sheets 9, 13, 14, 15, and 16 indicate areas of Excavation Of Unsuitable Materials at depths between 3’ and 6’ depth below the proposed profile. Is the intent in these areas to excavate to those depths to expose this material to determine if the material needs to be removed and replaced and/or the depth of undercut needed in these areas. Answer to Question j) did not indicate over excavation to these depths to determine in the field if the material is unsuitable, then re-filling, discing, and compacting these areas to meet the proposed subgrade.

ANSWER: Refer to Addendum #1 – Meeting Minutes – 8) Questions:

*“j) QUESTION: Do you know where the undercut areas are and where the unsuitable disposal will be? ANSWER: Excavation of unsuitable materials will be determined in the field during construction. Refer to Specification Section 03110, 3.03. Base Bid Item B3 is provided as contingency as needed. A disposal location will be designated on site.”*

In addition, disregard the callout, “EXCAVATION OF UNSUITABLE MATERIALS”, indicated in the profiles on drawing sheets: 9, 10, 13, 14, 15, and 16. No over-excavation will be needed, unless identified in the field.

3. QUESTION: Can excess topsoil be used as fill in non-structural areas (1:1 slope from edge of gravel on trails and parking lot)?

ANSWER: Yes, topsoil can be used as non-structural fill. The respread depth indicated in the details refers to a minimum 4” depth.



LAKE COUNTY FOREST PRESERVES

---

Preservation, Restoration, Education and Recreation

4. QUESTION: What size pipe is required at the temporary crossings?

ANSWER: Pipe size is left to the discretion of the contractor's judgment in evaluating the crossing location and installing a pipe that will maintain adequate flow for the duration of the temporary crossing.

---



Please **sign** this form and **return original** with your **bid**.

Sincerely,

Christine F. Miller  
Purchasing Manager

Acknowledged and Accepted:

Signature: \_\_\_\_\_

Company: \_\_\_\_\_

\_\_\_\_\_